



This document has been translated for informative purpose only.
Original version in German. In any case of doubt the German version is valid.

EC-CERTIFICATE OF CONFORMITY

0672 - CPD - 0079

In compliance with the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to the construction products (Construction Products Directive - CPD), amended by the Directive 93/68/EEC of the Council of European Communities of 22 July 1993, it has been stated that the construction products

Floor mounted door closers "GEZE TS 550 E-IS", "GEZE TS 550 E-IS-G"

with the classification enclosed in this certificate

placed on the market by

**GEZE GmbH
Reinhold-Vöster-Str. 21-29
D-71229 Leonberg**

and produced in the factory

**GEZE GmbH
Reinhold-Vöster-Str. 21-29
D-71229 Leonberg**

are submitted by the manufacturer to a factory production control and to the further testing of samples taken at the factory in accordance with a prescribed test plan and that the approved bodies have performed the initial type-testing for the relevant characteristics of the product, the initial inspection of the factory and of the factory production control and performs the continuous surveillance, assessment and approval of the factory production control.

This certificate attests that all provisions concerning the attestation of conformity and the performances described in Annex ZA of the standard

**EN 1154:1996 + A1:2002, EN 1155:1997 + A1:2002 and
EN 1158:1997 + A1:2002**

were applied and that the products fulfil all the prescribed requirements.

This certificate was first issued on March 21st, 2005, and remains valid as long as the conditions laid down in the harmonised technical specification in reference or the manufacturing conditions in the factory or the FPC itself are not modified significantly.

Stuttgart, March 21st, 2005

Materials testing institut – University of Stuttgart
Department of Mineral Construction Materials
Certification Body


(Akad. Dir. Dipl.-Ing. K. Zeus)
Head of the Certification Body





Enclosure to the EC–Certificate of Conformity

0672 – CPD – 0079

Classification of the door closers

GEZE TS 550 E-IS

EN 1154	4	8	6 3	1	1	4
---------	---	---	--------	---	---	---

EN 1155	3	8	6 3	1	1	4
---------	---	---	--------	---	---	---

EN 1158	3	8	6 3	1	1	4
---------	---	---	--------	---	---	---

GEZE TS 550 E-IS-G

EN 1154	4	8	6 3	1	1	4
---------	---	---	--------	---	---	---

EN 1155	3	8	6 3	1	1	4
---------	---	---	--------	---	---	---

EN 1158	3	8	6 3	1	1	4
---------	---	---	--------	---	---	---

Stuttgart, March 21st, 2005

Materials testing institut – University of Stuttgart
Department of Mineral Construction Materials
Certification Body


(Akad. Dir. Dipl.-Ing. K. Zeus)
Head of the Certification Body

