

# ift-Nachweis



## Evidence of Performance

Number	24-001673-PR03 (NW-D02-02-en-01)
Owner	GEZE GmbH Reinhold-Vöster-Str. 21-29 71229 Leonberg Germany
Product	Power operated automatic door one-leaf door
Designation	System: GEZE MCRdrive Profilsystem Shipping name: GEZE MCRdrive
Details	Manufacturer GEZE GmbH, - Leonberg; Material Aluminum and stainless steel; Opening direction Sliding door, to the left; Overall dimensions (W x H) 2,730 mm x 2,595 mm; Hardware GEZE GmbH; Infill LSG 12 mm, 0,76 SC out of 2 x Float 6 mm, Co. Schwabenglas
Special features	Glazed door Variant 1: without reinforcing Variant 2: with reinforcing

### Result

Air permeability according to EN 16361:2013+A1:2016



**Variant 1 Class: PPD1**

**Variant 2 Class: PPD1**

Air permeability based on EN 12207:2016-12



**Variant 1 Class: D**

**Variant 2 Class: D**

### Basis \*)

EN 16361-2013 + A1:2016-07

EN 14351-2:2018-11

\*) and corresponding national versions  
(e.g. DIN EN)

Test report: 24-001673-PR03 PB-  
D02-02-de-01

### Representation



### Instructions for use

The results obtained can be used by the manufacturer for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The provisions of the applicable product standard have to be observed.

### Validity

There is no time limit.

When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

### Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies. The cover sheet can be used as abstract.

ift Rosenheim

18.07.2024

Thomas Stefan, Dipl.-Ing. (FH)  
Head of Testing Department  
Building Component Testing

Daniel Gromotka, B.Eng.  
Operating Testing Officer  
Building Component Testing

### Identity-Check



[www.ift-rosenheim.de/ift-geprueft](http://www.ift-rosenheim.de/ift-geprueft)  
ID: 239-237B6

Ve-PB1-4902-en/ (01.04.2024)