

Certificate of constancy of performance

No. 0672-CPR-0051

In compliance with *Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the

Construction Product(s) **Overhead door closers**
"GEZE TS 4000 E" and "GEZE TS 4000 EFS"

with the classification enclosed in the annex 1 of this certificate

placed on the market
under the name or trade
mark of

GEZE GmbH
Reinhold-Vöster-Str. 21-29
71229 Leonberg
Germany

produced in the
manufacturing plant(s)

Plant 01

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in

Annex ZA
of the standard(s)

EN 1154:1996/A1:2002/AC:2006 and EN 1155:1997/A1:2002/AC:2006

under system

1

for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on **30.04.2014** and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

This document has been translated for informative purpose only. Original version is issued in German. In any case of doubt the German version is valid.



Dr. rer. nat. Andrea Bramborg-Kramer
Deputy Head of Certification Body



Annex 1

to the certificate of constancy of performance No. 0672-CPR-0051

Classification of the overhead door closers including their associated mounting variants

GEZE TS 4000 E

(door leaf mounting / hinge side
[normal mounting] and
transom mounting / opposite hinge side)

EN 1154

4	8	6 1	1	1	3
---	---	--------	---	---	---

EN 1155

3	8	6 1	1	1	3
---	---	--------	---	---	---

GEZE TS 4000 EFS

(door leaf mounting / hinge side
[normal mounting])

EN 1154

4	8	6 1	1	1	3
---	---	--------	---	---	---

EN 1155

3	8	6 1	1	1	3
---	---	--------	---	---	---

Hinweis: The manufacturer has to point out in the assembly and the adjustment documents of the door closers, that the door closer should be at least on size 3 for use on fire/smoke door assemblies.

Stuttgart, 19.12.2024

Materials Testing Institute – University of Stuttgart
Department Fire Protection
Certification Body

[Handwritten signature]

(Dr. rer. nat. Andrea Bramborg-Kramer)
Deputy Head of Certification Body

