

Certificate (English Issue)

Test number: **EP-13/2018**

Order: **1AU-135765**

Applicant: **GEZE GmbH
Reinhold-Vöster-Straße 21-29
71229 Leonberg**

Product: **Fittings for sliding doors**

Type: **„GEZE sliding fitting Rollan 40 NT“**

Test Centre **Association for Technical Inspection (TÜV) Thüringen e.V.
Test Centre for Building Industry Products
Am Köhlersgehäu 58
98544 Zella-Mehlis**

Test Report No.: **EP-13/2018**

Test specifications: **DIN EN 1527: 2013-03
DIN EN 1670: 2007-06 + Corrigendum 2008-07**

Test result: **The tested fittings are DIN EN 1527: 2013-03 classified as follows:**

numeral	1	2	3	4	5	6	7	8	9
class	--	4	1	--	1	1	--	1	3

Additions: **Test report No.: EP-13/2018 (5 pages report, 1 page Annex 01)**

Issue date: **2018-10-10**

Note: **The classification applies only to the audited fittings. Statements concerning quality and properties of other fittings cannot be extrapolated.**

Zella-Mehlis, 2018-10-10

**Association for Technical Inspection (TÜV) Thüringen e.V.
Test Centre for Building Industry Products**

**Graduate engineer (FH) Reichelt
Head of the testing centre**

